


# Installation Manual

## Unvented Flexistor Water Heaters

### Installation & Servicing Instructions



**Important**

**Please read & understand all these instructions before commencing installation.**

**This cylinder range does not incorporate an internal heat exchanger.**

**Please leave this manual with the customer for future reference.**



**Andrews. Built to perform.**

page 1

## **Contents**

### **Product Specification**

Introduction

General requirements

THE BENCHMARK™ SCHEME

Checklist

Storage and handling

Technical data

ErP data information

Immersion allocation table

Thermostat control schematics

Wiring Schematics

Limitations

Water supply

## **Installation & Commissioning**

General Installation

Cold Water Supply

Secondary circulation and De-Stratification

Discharge Pipe work

Direct Model

Commissioning

## **Maintenance & Servicing**

Maintenance requirements

Clean the strainer

Fault finding

Servicing

Spares

Accessories

Spares drawings

Benchmark check list

Service Record

## **Warranty**

25 Warranty Terms and Conditions



## **THE BENCHMARK™ SCHEME**

Benchmark™ places responsibilities on both manufacturers and installers. The purpose is to ensure that customers are provided with the correct equipment for their needs, that it is installed, commissioned and serviced in accordance with the manufacturer's instructions by competent persons and that it meets the requirements of the appropriate Building Regulations. The Benchmark™ Checklist can be used to demonstrate compliance with Building Regulations and should be provided to the customer for future reference. Installers are required to carry out installation, commissioning and servicing work in accordance with the Benchmark™ Code of Practice which is available from the Heating and Hotwater Industry Council who manage and promote the Scheme. Visit [www.centralheating.co.uk](http://www.centralheating.co.uk) for more information.

**IMPORTANT NOTE TO USER: PLEASE REFER TO THE USER GUIDE SECTION ON PAGES 34 FOR IMPORTANT INFORMATION WITH RESPECT TO THE BENCHMARK SCHEME**

page 2

## **Product specification**

### **Introduction**

Congratulations on your purchase of a Remeha Flexistor unvented water heater. The Remeha Flexistor products are manufactured in the UK from top quality materials and meets all the latest relevant safety and constructional standards. The high grade Duplex stainless steel cylinder offers exceptional strength

and corrosion resistance which is backed by a 30 year warranty\* Its performance and insulation levels exceed the latest requirements of Building Regulation Part L. The Remeha Flexistor unvented water heater can be fed directly from the cold water mains supply to the property without the need for separate feed cisterns or vent pipes. It is supplied complete with all its necessary inlet and safety controls. The Remeha Flexistor cylinder range all require a separate expansion vessel to accommodate any expanded water.

## **General Requirements**

**IMPORTANT:** Please read and understand this product guide before installing the Remeha Flexistor water heater. Incorrect installation may invalidate the warranty\*.

The Remeha Flexistor must be Installed, Commissioned and Maintained by a competent installer in accordance with Building Regulation G3 (England and Wales), Technical Standard P3 (Scotland) or Building Regulation P5 (Northern Ireland) and the Water Fitting Regulations (England and Wales) or Water Byelaws (Scotland).

**\* See Terms and Conditions of warranty**

**THIS APPLIANCE CAN BE USED BY CHILDREN AGED FROM 8 YEARS AND ABOVE AND PERSONS WITH REDUCED PHYSICAL, SENSORY OR MENTAL CAPABILITIES OR LACK OF EXPERIENCE AND KNOWLEDGE IF THEY HAVE BEEN GIVEN SUPERVISION OR INSTRUCTION CONCERNING USE OF THE APPLIANCE IN A SAFE WAY AND UNDERSTAND THE HAZARDS INVOLVED. CHILDREN SHALL NOT PLAY WITH THE APPLIANCE. CLEANING AND USER MAINTENANCE SHALL NOT BE MADE BY CHILDREN WITHOUT SUPERVISION**

**WARNING:** Do not switch on if there is a possibility that the water in the heater is frozen.

**Also:**

- water may drip from the discharge pipe of the pressure-relief device and this pipe must be left open to the atmosphere; (see [here](#) for more details)
- the pressure-relief device is to be operated regularly to remove lime deposits and to verify that it is not blocked; (see [here](#) for more details)
- how hot water can be drained. (see [here](#) for more details)
- A discharge pipe connected to the pressure-relief device is to be installed in a continuously downward direction and in frost free environment; (see [here](#) for details)
- details on how to set the temperature controls for immersion heaters can be found [here](#).

**Note:** This Remeha Flexistor cylinder needs a minimum 100L/min water supply at open outlet.

**Important Notice:**

**When installed with the KIWA approved unvented kit Remeha Flexistore cylinders are approved as meeting current water regulations.**

**To satisfy these regulations when the kit is not supplied it will be required that the installer ensures that all of the system components meet the required standards.**

## Checklist (if purchased through Heatrae Sadia)

Before commencing installation check that all the components for your Remeha Flexistor unit are contained in the package. The following components are supplied as standard with your Remeha Flexistor unit:

Commercial Cylinder Volume (ltr)	Pressure Reducing Valve	Pressure Relief Valve	Single Check Valve
400 - 500	1" Integrated inlet control valve		
800	1.25" (1.5 - 6 bar) or (5 -10 bar)	1" x 1.25" (8 bar) or (13 bar)	1.25"
1000	1.25" (1.5 - 6 bar) or (5 -10 bar)	1" x 1.25" (8 bar) or (13 bar)	1.25"
1250 - 1450	1.5" (1.5 - 6 bar) or (5 -10 bar)	1" x 1.25" (8 bar) or (13 bar)	1.5"
2000 - 2500	2" (1.5 - 6 bar) or (5 -10 bar)	1.25" x 1.5" (8 bar) or (13 bar)	2"

Table 1: Cold Water Inlet Control Kit (depending on model)

Commercial Cylinder Volume (ltr)	Expansion Vessel Size (ltr)	Mounting Kit	Weights
400 - 500	60	Floor Mounted	12kg
800	100	Floor Mounted	17kg
1000 - 1250	150	Floor Mounted	24kg
1450	200	Floor Mounted	38.5kg
2000 - 2500	300	Floor Mounted	41kg

Table 2: Expansion Vessel Sizing

- Factory fitted Temperature & Pressure Relief Valve, set at 90°C / 1 MPa (10bar) or factory fitted Temperature & Pressure Relief valve set at 90°C / 1.5MPa (15bar) Depending on model. Connection size 1 1/4" BSP male to cylinder and 1 1/4" BSP female outlet.

- Tundish 1 1/4" inlet, 1 1/2" outlet
- Isolating Valve (2")
- 1" Drain Valve.
- All connections BSP female.

**Notes:** 1" Integrated inlet control valve is not assembled.

page 4

## **Storage and Handling**

Please take care when handling a packaged Remeha Flexistor. The unit is heavy and must only be moved manually within safe working practices. If the unit is to be stored before installation, it must be placed on a secure, level surface and in a dry, frost free environment.

### **Precautions to be carried out prior to commencement of work:**

1. Tidy area ensuring there is safe access and egress to installation place, free from trip hazards.
2. Be aware of other people who may be in the area
3. Operate any machinery in accordance with training and operating instructions
4. Visually inspect the equipment prior to use, do not use damaged equipment.
5. Safe working practices are adopted for manual handling of appliances/parts
6. Correct PPE to be worn.

The Remeha Flexistor unit must be vertically floor mounted. It can be placed anywhere convenient provided the discharge pipe(s) from its safety valves can be correctly installed. Areas that are subject to freezing must be avoided. Ensure that the floor is level and of sufficient strength to support the "full" weight of the unit when filled with water (refer to Table 5 for unit weights). Pipe runs should be kept as short as possible for maximum economy. Access to associated controls, immersion heaters and indirect controls should be possible for servicing and maintenance of the system.

To aid installation, the Remeha Flexistor is provided with lifting points located at the top of the unit. To access the lifting eyes please remove the red outlet grommet and the top cover. The weights of the units are noted on Table 5.




FIGURE 1: Lifting

page 5

**Technical data (Indirect models in conformance with BS EN 12897:2016)**

Maximum mains water supply pressure	2.5MPa (25 bar)
Operating pressure/PRV (low pressure system)	0.60MPa (6. bar)
Operating pressure/PRV (high pressure system)	1.00MPa (10 bar)
Expansion vessel pressure (low pressure system)	1.0MPa (10 bar max)

Expansion vessel pressure (high pressure system)	1.6MPa (16 bar max)
Expansion relief valve setting (low pressure system)	0.8MPa (8 bar)
Expansion relief valve setting (high pressure system)	1.3MPa (13 bar)
Maximum design pressure (low pressure system)	0.80MPa (8 bar)
Maximum design pressure (high pressure system)	1.3MPa (13 bar)
T&P relief valve setting	1.0MPa/90 °C (10 bar)
T&P relief valve setting	1.5MPa/90 °C (15 bar)
Immersion heater rating (a.c. supply only) single phase	6kW & 9kW 50/60Hz ~
Immersion heater rating (a.c. supply only) 3 phase	12kW - 54kW 50/60Hz ~
(See <a href="#">Accessories</a> for full range)	
Storage weights (empty and full)	See <a href="#">Table 4</a>
	See <a href="#">Table 6</a>

## ErP data

ErP Data							
Model(s)	400	500	800	1000	1250	1450	2000
Energy efficiency class	B	C	C	C	C	C	C
Standing loss W	72.0	89.0	114.0	139.0	150.0	163.0	179.0

Storage volume V in Litres	400	500	800	1000	1250	1450	2000
----------------------------	-----	-----	-----	------	------	------	------

Table 3: ErP Data Information

Technical parameters in accordance with European Commission regulations 814/2013 and 812/2013

page 6




FIGURE 2: Flexistor Dimensions

	Connection 400 - 500L			Connection 800 - 1000L			Connection 1250 - 1450L			Connection 2000 - 2500L		
A	2" BSP	471	471	2" BSP	502	502	2" BSP	541	541	2"BSP	591	591
B	½"BSP	616	616	½"BSP	744	744	½"BSP	783	783	½"BSP	833	833

C	½"BSP	1138	1416	½"BSP	1502	1897	½"BSP	1466	1721	½"BSP	1493	1886
D	½"BSP	1001	1191	½"BSP	1263	1687	½"BSP	1326	1536	½"BSP	1376	1626
E	1 ¼" BSP	1138	1416	1 ¼" BSP	1502	1897	1 ¼" BSP	1466	1721	1 ¼" BSP	1493	1886
F	N/A	872	872	N/A	1024	1024	N/A	1224	1224	N/A	1470	1470
G	2" BSP	754	754	2" BSP	880	880	2" BSP	1042	1042	2" BSP	1077	1077
H	N/A	1535	1804	N/A	1906	2301	N/A	1936	2253	N/A	2014	2419

Table 4: Flexistor Dimensions




FIGURE 3: Flexistor Connections

**NOTE: All connections BSP female threads**

Nominal Capacity (Litres)	Unit Weight (kg)	
	Empty	Full
400	99	499

500	100	600
800	160	960
1000	180	1180
1250	297	1547
1450	304	1754
2000	415	2415
2500	421	2921

Table 5: Cylinder Weights

page 8

Nominal Capacity (Litres)	Per Day (kWh/24h)	Per Year kWh/24h)
400	1.72	627
500	2.14	781
800	2.74	1000
1000	3.33	1215
1250	3.60	1314
1450	3.90	1423
2000	4.30	1569

2500	4.50	1642
------	------	------

Table 6: Standing heat-loss

**Testing is carried out to BS EN12897:2016**

Nominal Capacity (Litres)	Maximum kW ratings		
	Lower boss	Upper boss	Total kW
400	30	9	39
500	45	12	57
800	45	18	63
1000	45	36	81
1250	54	30	84
1450	54	36	90
2000	54	36	90
2500	54	36	90

Table 7: Maximum kW ratings for auxiliary heating supply

Nominal Capacity (Litres)	Heat-Up Times		Nominal Capacity (Litres)	Heat-Up Times	
	Maximum kW	Heat-up Time (mins)		Maximum kW	Heat-up Time (mins)
400	39	32	1250	84	47

500	57	28	1450	90	51
800	63	40	2000	90	70
1000	81	39	2500	90	87

Table 8: Auxiliary heat up times based on maximum immersion input per cylinder

**Notes:**

**Times based on nominal volume**

**Times base on 45°C temperature rise**

page 9

**Immersion allocation Table**

Element	94110301		94110302		94110303		94110304		94110305		94110306		94110307		94110308		94110309		
Kw	6		9		12		18		24		30		36		45		54		
Location	Upper	Lower																	
Direct	400	✓	✓	✓	✓		✓		✓		✓		✓						
	500	✓	✓	✓	✓	✓	✓		✓		✓		✓		✓		✓		
	800	✓	✓	✓	✓	✓	✓	✓	✓		✓		✓		✓		✓		
	1000	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		✓		✓		
	1250	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		✓		✓		
	1450	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		✓
	2000	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	2500	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓

Table 9: Immersion allocation

**Note: The Immersion(s) are not factory fitted.**

**Thermostat Cut-out**

All immersion heaters are fitted with a thermostat which is fitted in the centre of the heater plate and a cut-out which is fitted to the side of the thermostat . These **MUST** be wired in series with the operating coil circuit of the contactor (not supplied). See [figures 4](#) below and [figures 5 & 6](#).

Maximum working temperature is 80°C/176°F. In very hard water areas limit to 60/65°C (140/150°F)

For optimal working conditions the thermal cut-out should be set to 80°C (factory set, if the seal is broken it may invalidate your warranty) and the thermostat should be set to 70°C max. If the thermostat is set above 70°C there could be instances nuisance tripping of the thermal cut-out.

**Notes:**

The 2 external contactors must be approved components certified for 10,000 cycles of operation for the contactor controlled by the thermostat and at least 30 for the contactor controlled by the none self-resetting thermal cut-out.




FIGURE 4: Thermostat and thermal cut-out settings

page 10

**Wiring Schematic**

**Single phase wiring schematic**




FIGURE 5: Single phase wiring schematic

**Note:**

The 2 external contactors must be approved components certified for 10,000 cycles of operation for the contactor controlled by the thermostat and at least 30 for the contactor controlled by the non-self-resetting thermal cut-out.

**3 phase wiring schematic**




FIGURE 6: 3 phase wiring schematic

page 11

### Limitations

- The Remeha Flexistor unvented water heater should not be used in any of the following instances:
- Solid fuel boilers or any other boiler in which the energy input is not under effective thermostatic control unless additional and appropriate safety measures are installed.
- Gravity circulation primaries.
- Steam heating plant unless additional and appropriate safety devices are installed.
- Ascending spray type bidets or any other Class 5 back syphonage risk requiring that a Type AA, AB, AD or AG air gap be employed.
- Water supplies that have either inadequate pressure or where the supply may be intermittent.
- Situations where it is not possible to safely pipe away any discharge from the safety valves.
- Areas where the water consistently contains a high proportion of solids, e.g. suspended matter that could block the strainer, unless adequate filtration can be ensured.
- The installation must be carried out in accordance with the relevant requirements of the appropriate Building Regulations: either The Building Regulations (England), The Building Regulations (Scotland) or Building Regulations (Northern Ireland), The Water Fittings Regulations (England and Wales) or Water Byelaws (Scotland).

### Water supply

Bear in mind that the mains water supply to the property will be supplying both the hot and cold water requirements simultaneously. It is recommended that the maximum water demand be assessed and the water supply checked to ensure this demand can be met. A minimum flow rate of 100l/min is required for the Remeha Flexistor range of cylinders

**NOTE:** A high mains water pressure will not always guarantee high flow rates.

Wherever possible the main supply pipe should be in 2". The minimum mains water supply requirements should be 0.15 MPa (1.5 bar) working pressure and minimum 100 litres per minute flow rate. At these values outlet flow rates may be poor if several outlets are used simultaneously, the higher the available pressure and flow rate the better the system performance will be.

The water supply must be of wholesome water quality (Fluid Category 1 as defined by the Water Supply Regulations 1999). The Remeha Flexistor is to be used for the storage of wholesome water (max. 250mg/l chloride).

**Note: In hard water areas it is recommended that service intervals are reduced to monitor scale build up on the immersion heaters.**

#### **Water container:**

Duplex stainless steel. 100% pressure tested to 2.25 MPa (22.5 bar).

page 12

## **Installation & Commissioning**

### **General installation**

#### **Pipe fittings**

All pipe connections to the Remeha Flexistor are made via BSP female parallel threaded pipe connection directly to the unit.

#### **Cold water supply**

A 2" cold water supply is recommended, however, if a smaller supply exists which provides sufficient flow this may be used. More flow noise may be experienced from small bore pipes due to the increased water velocity through them. A minimum flow rate of 100l/min is required for the Remeha Flexistor range of cylinders

#### **High flow cold water control pack (Low and high pressure)**

The control pack consists of a pressure reducing valve with integral strainer, check valve, core unit and expansion relief valve. The pressure settings are adjustable for the low or high pressure valve sets. For the "low" pressure valve set the pressure reducing valve can be set between 1.5 and 6 bar. For the "high" pressure valve set the pressure can be set between 5 and 10 bar. For optimum performance the following installation instructions should be complied with. Note: The expansion vessel pressure must be set in

accordance with the inlet pressure set on the pressure reducing valve by the installer. Set the Expansion Vessel pressure before pressurising the cylinder.

## **Installation**

Flush supply pipe work before connection to remove all flux and debris prior to fitting the inlet controls. Failure to do this may result in irreparable damage to the controls and will invalidate the warranty. The pressure reducing valve can be fitted in any orientation to suit the installation as long as it is fitted in the correct flow direction. Check the flow arrows on the side of the body. The expansion relief valve should be installed with the discharge pipe work in either the horizontal position or facing downwards, if the discharge pipe is facing upwards debris may be deposited on the seat of the valve when in operation.

The blank plastic plugs in the body of the pressure relief valve are pressure gauge connections to enable pressure monitoring to be carried out, should the system develop a fault. It is recommended that these be accessible (the pressure reducing valve has two - only one need be accessible). Expansion relief discharge pipe work must be connected to a safe visible discharge point via a tundish and the pipe work must have a continuous fall. If site conditions allow, the expansion relief discharge pipe work can be connected to the T&P valve discharge pipe work before the tundish.

## **Pressure reducing valve**

The pressure reducing valve can be connected anywhere on the cold water mains supply prior to the Remeha Flexistor unit. There is no requirement to site it close to the unit, it can be located at a point where the mains supply enters the premises if this is more convenient but you must install a non-return valve just after the reducing valve for ease of maintenance. The pressure reducing valve incorporates an adjustable pressure reducer / strainer. The valve can be fitted in any orientation to suit the installation, however, ensure that the valve is installed with the direction of flow arrows (stamped on the side of the brass body) pointing towards the Remeha Flexistor cylinder




Figure 07: Cold water combination valve (for 400 & 500ltr)




Figure 08: External heat source Thermal Cut-out




Figure 09: Schematic installations

Notes:

1. Primary heat source must be able to cope with working pressure of cylinder.
2. Secondary flow and return is wholesome water only.
3. There is no internal heat exchanger fitted to this cylinder range.

**Please note, that these are typical installations and other options are permissible**

page 15

## **Pressure Relief Valve**

This should be installed between the Pressure Reducing Valve and the Remeha Flexistor cylinder. Should a balanced pressure cold water draw off supply be required for the cold water outlets, this should be taken off between the Pressure Reducing Valve and Pressure Relief Valve. Branches to drinking water outlets should be taken before the Pressure Relief Valve to avoid the possibility of warm expanded water being drawn from the tap.

## **Drain valve**

It is recommended that the drain valve (supplied) be incorporated into the cold water inlet system, [Figure 9](#). It is recommended that the outlet point of the drain pipe work be at least 1 metre below the level of the heater (this can be achieved by attaching a hose pipe to the drain valve outlet spigot).

## **Outlet Pipe work**

Ideally the pipe work from the Remeha Flexistor to the outlet fittings should be in 2" pipe, smaller bore pipe can be used but it could impact on the performance of the unit. Small bore pipe can also be used to suit some taps, but runs should be of minimum length. Pipe sizes may vary due to system design.

## **Secondary Circulation**

If a secondary circulation system is required it is recommended that it be connected to the Remeha Flexistor similar to [Figure 9](#). The secondary return pipe should be in 28mm pipe and incorporate a check valve to prevent back flow, smaller pipe diameters can be used but may have a reduced flow. A suitable WRAS approved circulation pump will be required. On large systems, due to the increase in system water content, it may be necessary to fit additional expansion volume to the secondary system by fitting an external expansion vessel to the circuit. This should be done if the capacity of the secondary circuit exceeds 10 litres.

## **De-stratification kits**

The correct size of de-stratification kit must be used with your cylinder to ensure the volume can be circulated in 1 hour. The pump instructions will need to be reviewed for information on the correct setting. Please follow the installation schematic ([Figure 9](#)) for guidance. When the system circulates it needs to be specified by the installer to ensure water is not drawn off during the de-stratification process. If a hot water demand is required during this period cold water may be discharged from the hot outlet. It is recommended that a check valve be installed before the pump to stop any risk of cold water draw off through the pump when it is not in use. For guidance on installation please refer to [Figure 9](#).

## **External heat source**

If an external heat source is connected to the cylinder the control to the heat source must be wired via the over temperature cut-out supplied with the cylinder, alternatively it can be wired to the Primary circulation pump. This is to stop the external heat source from creating extreme temperatures within the cylinder. The secondary circulation must be wholesome water as there is no internal heat exchanger fitted to this cylinder range. The external heat source, if connected, must be able to withstand the cylinder working pressures

## **Tundish**

The tundish should not be located adjacent to any electrical components.

### **Pipe capacities (copper)**

22mm o/d = 0.38 litres per metre run (10 litres = 26m)

28mm o/d = 0.55 litres per metre run (10 litres = 18m)

35mm o/d = 0.83 litres per metre run (10 litres = 12m)

42mm o/d = 1.23 litres per meter run (10 litres = 8m)

page 16

## **The following extract is taken from latest G3 Regulations**

### **Discharge pipes from safety devices**

#### **Discharge pipe D1**

**3.50** Safety devices such as temperature relief valves or combined temperature and pressure relief valves (see paragraphs 3.13 or 3.18) should discharge either directly or by way of a manifold via a short length of metal pipe (D1) to a tundish.

**3.51** The diameter of discharge pipe (D1) should be not less than the nominal outlet size of the safety device, e.g. **temperature relief valve**.

**3.52** Where a manifold is used it should be sized to accept and discharge the total discharge from the discharge pipes connected to it.

**3.53** Where valves other than a temperature and pressure relief valve from a single unvented hot water system discharge by way of the same manifold that is used by the safety devices, the manifold should be factory fitted as part of the **hot water storage system unit** or package.

## **Tundish**

**3.54** The tundish should be vertical, located in the same space as the unvented hot water storage system and be fitted as close as possible to, and lower than, the safety device, with no more than 600mm of pipe between the valve outlet and the tundish (see Diagram 1).

**Note:** To comply with the Water Supply (Water Fittings) Regulations, the tundish should incorporate a suitable air gap.

**3.55** Any discharge should be visible at the tundish. In addition, where discharges from safety devices may not be apparent, e.g. in dwellings occupied by people with impaired vision or mobility, consideration should be given to the installation of a suitable safety device to warn when discharge takes place, e.g. electronically operated.

### **Discharge pipe D2**

**3.56** The discharge pipe (D2) from the tundish should:

1. have a vertical section of pipe at least 300mm long below the tundish before any elbows or bends in the pipework (see Diagram 1); and
2. be installed with a continuous fall of at least 1 in 200 thereafter.

**3.57** The discharge pipe (D2) should be made of:

1. metal; or
2. other material that has been demonstrated to be capable of safely withstanding temperatures of the water discharged and is clearly and permanently marked to identify the product and performance standard (e.g. as specified in the relevant part of BS 7291- 1:2006 Thermostatic pipes and fittings for hot and cold water for domestic purposes and heating installations in buildings. General requirements).

**3.58** The discharge pipe D2 should be at least one pipe size larger than the nominal outlet size of the safety device unless its total equivalent hydraulic resistance exceeds that of a straight pipe 9m long, i.e. for discharge pipes between 9m and 18m the equivalent resistance length should be at least two sizes larger than the nominal outlet size of the safety device; between 18 and 27m at least 3 sizes larger, and so on; bends must be taken into account in calculating the flow resistance. See Diagram 1, Table 3.1 and the worked example.

page 17

**Note:** An alternative approach for sizing discharge pipes would be to follow Annex D, section D.2 of BS 6700:2006 + A1:2009 Specification for design, installation, testing and maintenance of services supplying water for domestic use within buildings and their curtilages.

**3.59** Where a single common discharge pipe serves more than one system, it should be at least one pipe size larger than the largest individual discharge pipe (D2) to be connected.

**3.60** The discharge pipe should not be connected to a soil discharge stack unless it can be demonstrated that the soil discharge stack is capable of safely withstanding temperatures of the water discharged, in which case, it should:

1. contain a mechanical seal, not incorporating a water trap, which allows water into the branch pipe without allowing foul air from the drain to be ventilated through the tundish;

2. be a separate branch pipe with no **sanitary appliances** connected to it;
3. if plastic pipes are used as branch pipes carrying discharge from a safety device, they should be either polybutalene (PB) or cross-linked polyethylene (PE-X) complying with national standards such as Class S of BS 7291-2:2006 or Class S of BS 7291-3:2006 respectively; and
4. be continuously marked with a warning that no **sanitary appliances** should be connected to the pipe.

**Notes:**

1. Plastic pipes should be joined and assembled with fittings appropriate to the circumstances in which they are used as set out in BS EN ISO 1043-1:2002 Plastics. Symbols and abbreviated terms. Basic polymers and their special characteristics.
2. Where pipes cannot be connected to the stack it may be possible to route a dedicated pipe alongside or in close proximity to the discharge stack.

**Termination of discharge pipe**

**3.61** The discharge pipe (D2) from the tundish should terminate in a safe place where there is no risk to persons in the vicinity of the discharge.

**3.62** Examples of acceptable discharge arrangements are:

1. to a trapped gully with the end of the pipe below a fixed grating and above the water seal;
2. downward discharges at low level; i.e. up to 100mm above external surfaces such as car parks, hard standings, grassed areas etc. are acceptable providing that a wire cage or similar guard is positioned to prevent contact, whilst maintaining visibility; and,
3. discharges at high level: e.g. into a metal hopper and metal downpipe with the end of the discharge pipe clearly visible or onto a roof capable of withstanding high temperature discharges of water and 3 m from any plastic guttering system that would collect such discharges.

**3.63** The discharge would consist of high temperature water and steam. Asphalt, roofing felt and non-metallic rainwater goods may be damaged by such discharges.

page 18

**Discharge Pipe work**

It is a requirement of Building Regulations that any discharge from an unvented system is conveyed to where it is visible, but will not cause danger to persons in or about the building. The tundish and discharge pipes should be fitted in accordance with the requirements and guidance notes of Building Regulations. Building Regulation G3 Requirements and Guidance section 2 (page 17) are reproduced in the previous sections.

For discharge pipe arrangements not covered by G3 Guidance advice should be sought from your local Building Control Officer. Any discharge pipe connected to the pressure relief devices (Expansion Valve and Temperature / Pressure Relief Valve) must be installed in a continuously downward direction and in a frost free environment. The water may drip from the discharge pipe of the pressure relief device and that this pipe must be left open to the atmosphere. The pressure relief device is to be operated regularly to remove lime deposits and to verify that it is not blocked.

G3 Requirement "...there shall be precautions...to ensure that the hot water discharged from safety devices is safely conveyed to where it is visible but will not cause danger to persons in or about the building".

**Worked example of discharge pipe sizing (Taken from Building Regulations 2000, G3, 2010 edition)**

The example below is for a G1" temperature relief valve with a discharge pipe (D2) having 4 No. elbows and length of 7m from the tundish to the point of discharge. From Table 5: Maximum resistance allowed for a straight length of 35mm copper discharge pipe (D2) from a G1" temperature relief valve is 9m. Subtract the resistance for 4 No. 35mm elbows at 1.4m each = 5.6m Therefore the permitted length equates to: 3.4m 3.4m is less than the actual length of 7m therefore calculate the next largest size. Maximum resistance allowed for a straight length of 42mm pipe (D2) from a G1" temperature relief valve equates to 18m. Subtract the resistance of 4 No. 42mm elbows at 1.7m each = 6.8m Therefore the maximum permitted length equates to: 11.2m As the actual length is 7m, a 42mm (D2) copper pipe will be satisfactory.

**Warnings**

1. Under no circumstances should the factory fitted Temperature /Pressure Relief Valve be removed other than by authorised Heatrae Sadia personnel. To do so will invalidate any guarantee or claim.
2. The Cold Water Combination Valve must be fitted to the mains water supply to the Remeha Flexistor unit.
3. No control or safety valves should be tampered with or used for any other purposes.
4. Water may drip from the discharge pipe of the pressure relief device (Expansion Valve) and this pipe must be left open to atmosphere. The discharge pipe should not be blocked or used for any other purpose.
5. The tundish must be installed so that it is visible to the end user.
6. The tundish and drain valve must be installed away from any electrical components.
7. No valve should be fitted between the 8 bar or 13 bar pressure relief valve and the Remeha Flexistor unit.

page 19

**Notes:**

1. Discharge pipe-work D2 can now be a plastic pipe but only pipes that have been tested to a minimum 110°C must be used.
2. Discharge pipe D2 can now be plumbed in the soil stack but only soil stacks that can handle temperatures of 99°C or greater should be used.

<b>VALVE OUTLET  SIZE</b>	<b>MINIMUM SIZE OF  DISCHARGE PIPE D1</b>	<b>MINIMUM SIZE OF  DISCHARGE PIPE D2  FROM TUNDISH</b>	<b>MAXIMUM RESISTANCE  ALLOWED, EXPRESSED  AS A LENGTH OF STRAIGHT PIPE</b>	<b>RESISTANCE CREATED BY  EACH ELBOW OR BEND</b>

			<b>(I.E. NO ELBOWS OR BENDS</b>	
G 1/2	15mm	22mm	UP TO 9m	0.8m
		28mm	UP TO 18m	1.0m
		35mm	UP TO 27m	1.4m
G 3/4	22mm	28mm	UP TO 9m	1.0m
		35mm	UP TO 18m	1.4m
		42mm	UP TO 27m	1.7m
G 1	28mm	35mm	UP TO 9m	1.4m
		42mm	UP TO 18m	1.7m
		54mm	UP TO 27m	2.3m

Table 10 Sizing of copper discharge pipe "D2" for common T&P Relief Valve sizes.




Figure 10: Typical discharge pipe arrangement (Extract from Building Regulations G3 Guidance section 3.5 to 3.63)

page 20

### Immersion Heater(s)

The Remeha Flexistor can be fitted with a selection of single phase and three phase immersion heaters (see [Table 7](#) and element allocation [Table 9](#) for details). The immersion heaters must be installed in accordance with the installation instructions supplied with the immersion heater (supplied separately)

**Warning:** Before starting any work on the Megaflo commercial immersion heaters switch off all electrical supplies to such immersion heaters including thermostatic controls, these may be on a separate circuit.

### To remove the immersion heater:

Drain down the cylinder before any work is carried out on the Immersion heaters. Remove the immersion heater cover and disconnect all wiring from the immersion and thermostatic controls. Remove the 8 nuts (or bolts) and withdraw the immersion heater from the cylinder. Take care when lifting the immersion out of the cylinder and work within safe working practices.

## **Replacement:**

Make sure the Immersion heater gasket face is clean and if necessary replace the gasket (spare part number 95607396). Replace the Immersion heater and make sure the 8 nuts (or bolts) are correctly torqued (20Nm or 14.75 ft/lb) as per the Commercial Immersion heater fitting instructions (36006161). Wire up the immersion heater as per [Fig 5](#) or [Fig 6](#), or Remeha Flexistor immersion heater fitting instructions. Refill the cylinder and check for leaks. Turn on the supply and set the thermostat temperature to the desired water temperature (60°C - 65°C is recommended).

**NOTE: If using fibre gaskets they should be pre-soaked in ambient temperature water for 30 mins before installation and the 8 securing nuts are diametrically tightened to 20 Nm or 0.42psi. White silicone gaskets can be fitted directly.**

## **Wiring (See [Figures 4, 5 & 6](#))**

All electrical wiring should be carried out by a competent electrician and be in accordance with the latest I.E.E. Wiring Regulations BS 7671.

**DO NOT OPERATE THE IMMERSION HEATER(S) UNTIL THE Remeha Flexistor HAS BEEN FILLED WITH WATER.**

## **Operation**

See [Fig 4](#), for details on how to adjust the temperature setting of the heater.

**DO NOT BYPASS THE THERMAL CUT-OUT IN ANY CIRCUMSTANCES.**

page 21

## **Commissioning**

### **Filling and flushing the Remeha Flexistor**

Ensure that all fittings and immersion heaters are correctly fitted and tightened.

1. Open a hot tap furthest from the Remeha Flexistor.
2. Open the mains stop cock to fill the unit. When water issues from the tap, allow to run for a few minutes to thoroughly flush through any residue, dirt or swarf, then close tap.
3. Open successive hot taps to purge any air from the system.
4. Check all connections for leaks and rectify as necessary.
5. The Strainer housed within the Pressure Reducing Valve should be cleaned to remove any debris that may have been flushed through the main supply pipe.

### **Check the operation of the Safety Valves**

1. Slowly, manually open for a few seconds, the Temperature and Pressure Relief Valve (T&P Valve) situated on the Remeha Flexistor unit. Check water discharged runs freely away through the tundish and discharge pipe work. Close valve, ensure water flow stops and valve reseats correctly.
2. Repeat for the Pressure Relief Valve.

**NOTE:** The water discharged may be very hot.

### **Primary Heat source (when fitted)**

Connect up primary heat source as per manufacturers instructions. Fill up primary and secondary circuits, bleeding any air that may be trapped and check for leaks. Make sure secondary circuit has wholesome water only, the Flexistor range of cylinders do not have an internal heat exchanger. Take care that the Primary Heat source can handle the working pressure of the cylinder.

### **Auxiliary power supply (Immersion Heaters)**

Switch on the electrical supply to the immersion heater(s) and allow the unit to heat up. Check that the thermostat operates correctly. A storage temperature of approx. 60°C is recommended, install and set up immersions as per immersion heater fitting instructions (36006161) . Check that no water is discharged from either the Expansion Valve or Temperature and Pressure Relief Valve during the heating cycle. The thermal cut-out is factory set to 80°C max for direct heating

### **BENCHMARK™ Log Book**

On completion of the installation and commissioning procedures detailed in this Product Guide the BENCHMARK™ "Installation, Commissioning and Service Record Log" should be completed and signed off by the competent installer or commissioning engineer in the relevant sections. The various system features, location of system controls, user instructions and what to do in the event of a system failure should be explained to the customer. The customer should then countersign the BENCHMARK™ commissioning checklist to accept completion. The Service Record should be filled in when any subsequent service or maintenance operation is carried out on the Remeha Flexistor unit. See BENCHMARK™ logbook and service record

page 22

## **Maintenance & Servicing**

### **Maintenance requirements**

To ensure the continued optimum performance of the Remeha Flexistor it should be regularly maintained. This is of particular importance in hard water areas or where the water supply contains particulate matter. Maintenance should be carried out by a competent person and any replacement parts used should be authorised Remeha Flexistor spare parts. It is recommended that maintenance is carried out every 12 months and includes the checks detailed below. In hard water areas consideration should be given to periodically descaling the immersion heater elements. To do this the Remeha Flexistor unit will need to be drained.

## **Check operation of Safety Valves**

Slowly open the Temperature and Pressure Relief Valve by twisting its cap for a few seconds. Check water is discharged and that it flows freely through the tundish and discharge pipe work. Check valve reseats correctly when released.

**NOTE:** The water discharged may be very hot.

Repeat the procedure for the Pressure Relief Valve.

## **Inspection**

The immersion heater boss can be used as an access for inspecting the cylinder internally.

## **Clean the strainer**

The strainer is incorporated within the Pressure Reducing Valve housing of the Valve. To inspect and clean the strainer:

1. Turn off the isolating valve prior to the Pressure Reducing Valve or the main stop cock to the system.
2. Open the lowest hot tap in the system to relieve the system pressure.
3. Using a spanner unscrew the pressure reducing cartridge and remove the moulded housing. The strainer will be removed with the cartridge.
4. Wash any particulate matter from the strainer under clean running water.
5. Replace the strainer and screw the Pressure Reducing Valve cartridge into the moulded housing.
6. Close hot tap, turn on isolating valve or main stop cock to the system. Check for leaks.

## **Draining the Cylinder**

Switch off the electrical supply to the immersion heater(s) and primary heat source, if used. Turn off the mains water supply to the Remeha Flexistor unit. Attach a hosepipe to the drain valve having sufficient length to take water to a suitable discharge point below the level of the unit, at least one metre below the unit is recommended. Open hot water tap nearest to the Remeha Flexistor to relieve the system pressure. Open drain valve. If water fails to drain from the Remeha Flexistor vent the unit by manually opening the Temperature / Pressure Relief Valve.

## **Refilling system**

**DO NOT** switch on the immersion heater(s) or primary heat source until the system has been completely refilled.

Close the drain valve. With the hot tap open, turn on mains water supply. When water flows from the hot tap allow to flow for a short while to purge air and to flush through any disturbed particles. Close hot tap and then open successive hot taps in system to purge any air. The electrical supply can now be switched on.

## **BENCHMARK™**

On completion of any maintenance or service of the Megaflo Commercial, the BENCHMARK™ "Installation, Commissioning and Service Record", should be filled in to record the actions taken and the date the work was undertaken.

### **Maintenance**

Under normal circumstances the control valves should not require any maintenance. However, annual inspection and/or cleaning of the integral strainer, pressure reducing valve cartridge, expansion relief valve cartridge and seating may be necessary depending on local water conditions.

#### **Pressure reducing valve**

Isolate cold water supply and drain system if necessary. Unscrew the retaining nut of the valve. The complete operating mechanism, including the strainer can be removed. Clean the filter mesh and cartridge ensuring that the strainer is correctly located and reassemble the unit.

#### **Expansion Valve**

Isolate cold water supply. Unscrew expansion relief cartridge from body and clean the filter mesh and cartridge. Clean valve seat face and seating - do not scratch or damage either seal face or seating. Refit in reverse order. Do not over tighten.

### **Warnings**

**IF WATER DISCHARGES FROM THE TEMPERATURE / PRESSURE RELIEF VALVE ON THE Remeha Flexistor UNIT REFER TO FAULT FINDING TABLE FIRST FOR GUIDANCE. IF THIS DOES NOT RECTIFY THE FAULT SWITCH OFF ELECTRICAL SUPPLY TO THE IMMERSION HEATER(S) [AUXILIARY HEATING] OR SHUT DOWN THE EXTERNAL HEAT SOURCE [IF CONNECTED]. DO NOT TURN OFF THE WATER SUPPLY. CONTACT A COMPETENT INSTALLER FOR UNVENTED WATER HEATERS TO CHECK THE SYSTEM.**

**DO NOT TAMPER WITH ANY OF THE SAFETY VALVES FITTED TO THE MEGAFLO COMMERCIAL FLEXISTOR SYSTEM, IF A FAULT IS SUSPECTED CONTACT A COMPETENT INSTALLER.**

page 24

## **Fault finding**

The Fault Finding chart will enable operational faults to be identified and their possible causes rectified. Any work carried out on the Remeha Flexistor unvented water heater and its associated controls **MUST** be carried out by a competent installer for unvented water heating systems. In case of doubt contact the Remeha Flexistor Service Department.

<b>Fault</b>	<b>Possible Cause</b>	<b>Remedy</b>
No hot water flow	Mains water supply off	Check and open stop cock/isolating valve
	Strainer blocked	Turn off water supply, remove strainer and clean
	Cold water combination valve incorrectly fitted	Check and refit as required
Water from hot tap is cold	Auxiliary immersion heater not switched on	Check and switch on
	Auxiliary immersion heater thermal cutout has operated	Check, reset by pushing button on thermal cutout
	External heat source not switched on	Check, turn on external heat source
	External heat source not working	Check heat source operation. If fault is suspected consult heat source manufacturer's instructions
	External heat source thermal cut-out has operated	Check, reset by pushing button on thermal cutout Check operation of heat source thermostat
Water discharges from overflow visual indicator (tundish)	INTERMITTENTLY	Incorrect pre-charge pressure for expansion vessel
	CONTINUALLY	Check pressure from pressure reducing valve
		Remove expansion relief cartridge from pressure relief valve and check seating. If necessary fit new cartridge
Water discharges from the T&P relief valve intermittently	Expansion relief valve faulty	Check valve and replace if necessary

Water discharges from the T&P relief valve continually	Thermal control failure <b>NOTE:</b> Water will be very hot	Switch off power to immersion heater(s) and shut down external heat source. <b>DO NOT</b> turn off water supply. When discharge stops check all thermal controls, replace if faulty
Performance has deteriorated	GRADUALLY	Check for scale build up in the DHW heat exchanger

Table 11 - Fault finding guide.

## Servicing

### Important

1. Servicing should only be carried by an authorised Engineer, Agents or by installers competent in the installation and maintenance of unvented water heating systems.
2. Any spare parts used **MUST** be authorised Remeha Flexistor parts.
3. Disconnect the electrical supply before removing any electrical equipment covers.
4. **NEVER** bypass any thermal controls or operate system without the necessary safety valves.
5. Water contained in the Remeha Flexistor unit may be very hot, especially following a thermal control failure. Caution must be taken when drawing water from the unit.

page 25

### Spare parts

A full range of spare parts are available for the Remeha Flexistor range. Refer to the Technical Data label on the unit to identify the model installed and ensure the correct part is ordered.

Key	Description	Spares Number
1	Immersion Heater Gasket	95611025
2	Blanking Plate Kit	95607396
4	Expansion Vessel 60L 6 Bar	95607445
6	Expansion Vessel 100L 6 Bar	95607458
7	Expansion Vessel 150L 6 Bar	95607461

8	Expansion Vessel 200L 6 Bar	95612723
9	Expansion Vessel 300L 6 Bar	95612724
10	1" Integrated Inlet Control Valve 5-10Bar	95605176
11	Isolating Ball Valve 1"	95605178
12	Isolating Ball Valve 1 1/4"	95605179
13	Isolating Ball Valve 1 1/2"	95605180
14	Isolating Ball Valve 2"	95605181
15	Isolating Drain Valve 1"	95605182
16	Tundish 1 1/2" X 2"	95607452
17	Prv 1 1/4" Set Pressure 1.5 To 6 Bar Max Ip 16 Bar	95605183
18	Prv 1 1/4" Set Pressure 5 To 10 Bar Max Ip 16 Bar	95605184
19	Prv 1 1/2" Set Pressure 1.5 To 6 Bar Max Ip 16 Bar	95605185
20	Prv 1 1/2" Set Pressure 5 To 10 Bar Max Ip 16 Bar	95605186
21	Prv 2" Set Pressure 1.5 To 6 Bar Max Ip 16 Bar	95605187
22	Prv 2" Set Pressure 5 To 10 Bar Max Ip 16 Bar	95605188
23	Single Check Valve 1 1/4"	95605189
24	Single Check Valve 1 1/2"	95605190
25	Single Check Valve 2"	95605191

26	Expansion Relief Valve 1" X 1 1/4" Set Pressure 8 Bar	95605192
27	Expansion Relief Valve 1" X 1 1/4" Set Pressure 13 Bar	95605193
28	Expansion Relief Valve 1 1/4" X 1 1/2" Set Pressure 8 Bar	95605194
29	Expansion Relief Valve 1 1/4" X 1 1/2" Set Pressure 13 Bar	95605195
30	Temperature And Pressure Relief Valve - Set Pressure 10 Bar	7033371
31	Temperature And Pressure Relief Valve - Set Pressure 15 Bar	95605197
32	Dual Control Thermostat	95612650
33	Cut-out thermostat	7031593
34	Rod thermostat	95980025
35	Pump 3 speed circulation up 20-30n	95607366
36	Pump 3 speed circulation ups 15-50n 130	95607404
37	28mm pump isolating valve	95605177
38	1/2" blanking stat pocket	95607690
40	Expansion vessel 60l 10 bar	95607446
41	Expansion vessel 100l 10 bar	95607459
42	Expansion vessel 150l 10 bar	95607462
43	Expansion vessel 200l 10 bar	95612725
44	Expansion vessel 300l 10 bar	95612726




45	1" integrated inlet control valve 1-6bar	95605109
46	Over temperature rod thermostat	95980009
48	2" BSP blanking plug	7038680



page 26

## Accessories


<b>Immersion</b>	<b>Part number</b>
6kW Commercial Immersion - Single phase	94110301
9kW Commercial Immersion - Single phase	94110302
12kW Commercial Immersion - Three phase	94110303
18kW Commercial Immersion - Three phase	94110304
24kW Commercial Immersion - Three phase	94110305
30kW Commercial Immersion - Three phase	94110306
36kW Commercial Immersion - Three phase	94110307
45kW Commercial Immersion - Three phase	94110308
54kW Commercial Immersion - Three phase	94110309
Busbar Conversion Kit	94970110
De-Stratification loop kit - 400-500 litre	95970140
De-Stratification loop kit - 800-1450 litre	95970157


De-Stratification loop kit - 2000-2500 litre	95970158
Temperature gauge	95970141
Pressure gauge	95970142
Temperature gauge (calibrated)	95970017
Pressure gauge (calibrated)	95970016
Flexistor 400/500L 6 bar cold water control kit	7038498
Flexistor 800L 6 bar cold water control kit	7038499
Flexistor 1000L 6 bar cold water control kit	7038500
Flexistor 1250L 6 bar cold water control kit	7038501
Flexistor 1450L 6 bar cold water control kit	7038502
Flexistor 2000/2500L cold water control kit	7038503
Flexistor 400/500L 10 bar cold water control kit	7038504
Flexistor 800L 10 bar cold water control kit	7038505
Flexistor 1000L 10 bar cold water control kit	7038506
Flexistor 1250L 10 bar cold water control kit	7038507
Flexistor 1450L 10 bar cold water control kit	7038508
Flexistor 2000/2500L 10 bar cold water control kit	7038509

1		2	
Part No:	95:611:025	Part No:	95:607:396
4-9 43-47		10-48	
Part No:	95:607:___	Part No:	95:605:___
11-14		15	
Part No:	95:605:___	Part No:	95:605:182


16		17-22	
Part No:	95:607:452	Part No:	95:605:___

page 28


23-25		26-29	
Part No:	95:605:___	Part No:	95:605:___






Part No:	95:605:___	Part No:	95:612:650
----------	------------	----------	------------




Part No:	7031593	Part No:	95:980:025
----------	---------	----------	------------



Part No:	95:607:___	Part No:	95:605:177
38		46	
Part No:	95:607:690	Part No:	95:980:009





**MAINS PRESSURE HOT WATER STORAGE SYSTEM  
COMMISSIONING CHECKLIST**

This Commissioning Checklist is to be completed in full by the competent person who commissioned the storage system as a means of demonstrating compliance with the appropriate Building Regulations and then handed to the customer to keep for future reference.

Failure to install and commission this equipment to the manufacturer's instructions may invalidate the warranty but does not affect statutory rights.

Customer Name \_\_\_\_\_ Telephone Number \_\_\_\_\_  
Address \_\_\_\_\_  
Cylinder Make and Model \_\_\_\_\_  
Cylinder Serial Number \_\_\_\_\_  
Commissioned by (print name) \_\_\_\_\_ Registered Operative ID Number \_\_\_\_\_  
Company Name \_\_\_\_\_ Telephone Number \_\_\_\_\_  
Company Address \_\_\_\_\_ Commissioning Date \_\_\_\_\_

To be completed by the customer on receipt of a Building Regulations Compliance Certificate\*:

Building Regulations Notification Number (if applicable) \_\_\_\_\_

#### ALL SYSTEMS PRIMARY SETTINGS (indirect heating only)

Is the primary circuit a sealed or open vented system? Sealed  Open   
What is the maximum primary flow temperature? \_\_\_\_\_ °C

#### ALL SYSTEMS

What is the incoming static cold water pressure at the inlet to the system? \_\_\_\_\_ bar  
Has a strainer been cleaned of installation debris (if fitted)? Yes  No   
Is the installation in a hard water area (above 200ppm)? Yes  No   
If yes, has a water scale reducer been fitted? Yes  No   
What type of scale reducer has been fitted? \_\_\_\_\_  
What is the hot water thermostat set temperature? \_\_\_\_\_ °C  
What is the maximum hot water flow rate at set thermostat temperature (measured at high flow outlet)? \_\_\_\_\_ l/min  
Time and temperature controls have been fitted in compliance with Part L of the Building Regulations? Yes   
Type of control system (if applicable) Y Plan  S Plan  Other   
Is the cylinder solar (or other renewable) compatible? Yes  No   
What is the hot water temperature at the nearest outlet? \_\_\_\_\_ °C  
All appropriate pipes have been insulated up to 1 metre or the point where they become concealed Yes

#### UNVENTED SYSTEMS ONLY

Where is the pressure reducing valve situated (if fitted)? \_\_\_\_\_  
What is the pressure reducing valve setting? \_\_\_\_\_ bar  
Has a combined temperature and pressure relief valve and expansion valve been fitted and discharge tested? Yes  No   
The tundish and discharge pipework have been connected and terminated to Part G of the Building Regulations Yes   
Are all energy sources fitted with a cut out device? Yes  No   
Has the expansion vessel or internal air space been checked? Yes  No

#### THERMAL STORES ONLY

What store temperature is achievable? \_\_\_\_\_ °C  
What is the maximum hot water temperature? \_\_\_\_\_ °C

#### ALL INSTALLATIONS

The hot water system complies with the appropriate Building Regulations Yes   
The system has been installed and commissioned in accordance with the manufacturer's instructions Yes   
The system controls have been demonstrated to and understood by the customer Yes   
The manufacturer's literature, including Benchmark Checklist and Service Record, has been explained and left with the customer Yes

Commissioning Engineer's Signature \_\_\_\_\_

Customer's Signature \_\_\_\_\_  
(To confirm satisfactory demonstration and receipt of manufacturer's literature)

\*All installations in England and Wales must be notified to Local Authority Building Control (LABC) either directly or through a Competent Persons Scheme. A Building Regulations Compliance Certificate will then be issued to the customer.



## **SERVICE RECORD**

It is recommended that your hot water system is serviced regularly and that the appropriate Service Record is completed.

### **Service Provider**

Before completing the appropriate Service Record below, please ensure you have carried out the service as described in the manufacturer's instructions.



# User Guide

## 25 year Warranty Terms and Conditions

**WARNING:** Should the factory fitted temperature and pressure relief valve be tampered with or removed your guarantee will be invalidated. Neither the Distributor nor Manufacturer shall be responsible for any consequential damage howsoever caused.

### Warranty Terms

Andrews commercial guarantees the product against faulty manufacture or materials for a period of two years from the date of purchase including parts and labour. This two year guarantee is extended to five years for the cold water control valve and to 25 years (from the date of installation) for the stainless steel inner vessel.

#### These guarantees are valid provided that:

- The unvented water heater has been installed by a competent engineer and as per the instructions contained in the installation manual and all relevant Codes of Practice and Regulations in force at the time of installation.
- Any disinfection has been carried out in accordance with BS EN 806
- Should the factory fitted temperature and pressure relief valve be tampered with or removed your guarantee will be invalidated.
- The Andrews water heater unit has not been modified in anyway other than by approved engineers.
- The Andrews water heater unit has only been used for the storage of wholesome sanitary water (max 250mg/l chloride).
- Only stainless steel dummy plugs are to be used.
- The Andrews water heater has not been subjected to excessive pressure beyond the guidelines detailed in the installation instructions.
- The Andrews water heater has not been subjected to frost, nor has it been tampered with or been subject to misuse or neglect.
- No factory fitted parts have been removed for unauthorised repair or replacement
- Regular maintenance has been carried out by a competent person in accordance with the requirements set in the maintenance section of the installation manual and any replacement parts used should be approved spare parts.
- The original warranty period will apply to any parts replaced

#### The warranty does NOT cover:

Any consequential damages or profit loss which may arise from a defect. Warranty claims have no delaying effect on the payment dates and other demands

Your Andrews Commercial warranty covers you for a direct replacement and labour in the event that the unit fails prematurely as a result of a proved manufacturing defect.

Andrews is not responsible for any damage that has been caused by incorrect or defective installation, commissioning, water treatment, service or maintenance. Our current technical documentation can be taken as the basis for this.

In order that this can be achieved, full access to replace the unit is essential. If it is found that access can not be achieved the warranty will be limited to the replacement of the unit only and subsequent labour charges would not be met under the warranty.

page 34

## **The Environment**

This product is made from many recyclable materials, therefore at the end of its useful life it should be disposed of at a local authority recycling centre in order to realise the full environmental benefits. Insulation is by means of an approved HCFC/CFC free polyurethane foam.

## **WEEE Declaration**

Disposal of Waste Equipment by Users in Private Households in the European Union.



This symbol on the product indicates that this product must not be disposed of with your other household waste. Instead, it is your responsibility to dispose of your waste equipment by handing it over to a designated collection point for the recycling of waste electrical equipment. The separate collection and recycling of your waste equipment at the time of disposal will help to conserve natural resources and ensure that it is recycled in a manner that protects human health and the environment. For more information about where you can drop off your waste equipment for recycling, please contact your local city office, your household waste disposal service or the company where this product was purchased.

## **Spares stockists**

### **Customer service**

#### **Telephone**

**0345 070 1058**

page 35



Register now to activate your warranty [www.andrewswaterheaters.co.uk/register-a-warranty](http://www.andrewswaterheaters.co.uk/register-a-warranty) . Please make sure you attach proof of purchase for your warranty to be monitored.

All descriptions and illustrations provided in this document have been carefully prepared but we reserve the right to make changes and improvements in our products which may affect the accuracy of the information contained in this leaflet. All goods are sold subject to our standard Conditions of Sale which are available on request.

## Customer support


8am-5pm, Monday-Friday

Tel 0345 070 1057

Web [andrewswaterheaters.co.uk](http://andrewswaterheaters.co.uk)

 [linkedin.com/company/andrews-water-heaters](https://www.linkedin.com/company/andrews-water-heaters)

 @AndrewsWH



**Andrews. Built to perform.**

a Baxi Heating brand

Registered office address:

Baxi Heating UK,

Brooks House,

Coventry Road,

Warwick

CV34 4LL

7038476\_issue\_01

page 36

